

**October 2003**  
**FACT SHEET**  
**Navajo Tribal Utility Authority-Ganado**  
**NPDES Permit No. AZ0022195**

**I.     Introduction**

The Navajo Tribal Utility Authority ("NTUA") was issued an NPDES permit (AZ0022195) on August 10, 1987 for the Ganado wastewater treatment lagoons. The permit became effective on September 21, 1987 and expired on June 30, 1992. NTUA applied to U.S. Environmental Protection Agency (EPA) Region 9 for reissuance on June 11, 1998. EPA issued another permit on November 01, 1998 which will expire on October 31, 2003. NTUA submitted an application for continued coverage of the NPDES permit on July 9, 2003.

Applicant address: Navajo Tribal Utility Authority  
P.O. Box 170  
Ft. Defiance, AZ 86504

Applicant Contact: Harry Begaye  
(520) 729-5721 (ext. 2208)

Facility Contact: Daniel Wauneka  
(928) 674-5470

**II.    Background**

The NTUA-Ganado wastewater treatment lagoons are located one mile west of Hubbell Trading Post in Ganado, Apache County, approximately 0.5 miles south of Arizona Highway 264, in the central portion of the Navajo Nation, Arizona. The facility serves a population of about 4,000, receiving only domestic sewage with a design flow of 0.40 million gallons per day (MGD).

The treatment plant is a two-cell (evaporation ponds) aerated lagoon type treatment system. Wastewater from the collection system flows by gravity to a bar screening unit and then to a lift station. Transfer piping allows wastewater to flow in succession from aerated Cell#1 to Cell #2. Final effluent is chlorinated and discharged from a 13-inch pipe into Outfall No. 001 to receiving waters named Pueblo Colorado Wash (ephemeral), a tributary to Cottonwood Wash, an eventual tributary to the Little Colorado River. Any sampling and monitoring under the proposed permit shall be performed at Outfall No. 001.

The bar screen unit has backed-up on occasions causing wastewater to overflow out of both the bar screen unit and the first manhole upgradient from the bar screen unit.

Wasterwater overflowing from the bar screen unit pools and eventually enters into the Pueblo Colorado Wash. This discharge is not authorized by the 1998 permit and will not be authorized by the new permit.

EPA has determined that there are no threatened or endangered species of concern in the discharge area so no requirements specific to the protection of endangered species are in the proposed permit. A copy of the permit and fact sheet is being sent to the U.S. Fish and Wildlife Service for review during the public comment period.

### III. Navajo Nation Water Quality Standards

Pursuant to the Water Quality Act of 1987 and the "EPA Policy for the Administration of Environmental Programs on Indian Reservations" (November 8, 1987), EPA will work directly with Indian Tribal governments on a one-to-one basis. This conforms with the Federal Indian Policy of January 24, 1983. The Navajo Nation has received Treatment as a State (TAS) for Section 106 of the Clean Water Act ("CWA".) They have applied but have not received TAS for the purposes of Section 303 of the CWA. Section 106 grant money was used to develop water quality standards and use designations, which must be approved under Section 303 by EPA Region 9. The Navajo Nation completed and adopted the Navajo Nation Surface Water Quality Standards ("NNSWQS") on September 7, 1999 and promulgated in November 1999. The NNSWQS, along with a TAS application under Section 303, was submitted to EPA in November 1999. A draft revision to the NNSWQS made on April 17, 2003 is awaiting review and approval by the Navajo Nation Council. In the interim until the NNSWQS are approved by EPA, those water quality standards will be used on a best professional judgment basis for purposes of developing water quality based effluent limitations.

### IV. Basis of Proposed Permit Requirements

The proposed discharge limitations are based upon:

- A. Secondary Treatment Regulations contained in 40 CFR Part 133, Sections 133.101 through 133.105, promulgated September 20, 1984, and most recently amended on January 27, 1989.
- B. NNSWQS, which was promulgated by the Navajo Nation Council in November 1999.

### V. Designated Uses of the Receiving Water

The designated uses of the receiving water (Little Colorado River, Cottonwood Wash within Navajo Nation boundary) as defined by the NNSWQS are

secondary human contact, ephemeral warm water habitat, and livestock and wildlife watering (Table 204.1, page 19.)

## VI. Determination of Effluent Limitations, Monitoring and Reporting Requirements

### A. Flow Rates

Under the proposed permit, there is no flow limit but the monthly and daily maximum flows must be monitored and reported. The monitoring frequency is once/week. This is consistent with the previous permit.

### B. Five-Day Biochemical Oxygen Demand (BOD<sub>5</sub>)

Under the proposed permit, the discharge shall not exceed a monthly average of 45 mg/l and a weekly average of 65 mg/l, and shall achieve no less than a monthly average rate of 65% removal. These limits are required under 40 CFR Section 133.105(a) and 133.115(d). The limits are designated as 30-day and 7-day averages since the facility operates similarly to a POTW [40 CFR 122.45(d)]. These limits are the same as those in the previous permit.

Under 40 CFR Section 122.45(f), mass limits are required for BOD<sub>5</sub>. Based upon the 0.40 MGD flow, the mass limits for BOD<sub>5</sub> are based on the following calculations:

#### Monthly average

$$\frac{0.40 \text{ MG}}{\text{day}} \times \frac{45 \text{ mg}}{1} \times \frac{8.345 \text{ lb/MG}}{1 \text{ mg/l}} \times \frac{0.45 \text{ kg}}{\text{lb}} = 68.0 \text{ kg/day}$$

#### Weekly average

$$\frac{0.40 \text{ MG}}{\text{day}} \times \frac{65 \text{ mg}}{1} \times \frac{8.345 \text{ lb/MG}}{1 \text{ mg/l}} \times \frac{0.45 \text{ kg}}{\text{lb}} = 98.0 \text{ kg/day}$$

The monitoring frequency is once/week. These limits are identical to those in the previous permit.

### C. Total Suspended Solids (TSS)

Under the proposed permit, the discharge shall not exceed a weekly average of 135 mg/l and monthly average of 90 mg/l TSS, and shall achieve no less than a monthly

average rate of 65% removal. These limitations (Alternative State Requirements) are Best Professional Judgment technology-based limits and consistent with 40 CFR Sections 133.105(b)(3) and (d). Mass limit requirements in accordance with 40 CFR 122.45(f) have also been set in the proposed permit. Mass loadings are based upon the same calculation shown above for BOD<sub>5</sub> and shall not exceed a 7-day average of 203.0 kg/day and a monthly average of 135.0 kg/day for TSS. The monitoring frequency is once/week.

D. Fecal Coliform

Under the proposed permit, the monthly logarithmic mean of fecal bacteria shall not exceed 200/100 ml, as a geometric mean of samples collected during the calendar month, and 400/100 ml as a single sample maximum. These limits are more stringent than those in the previous permit and are based on the Navajo Nation Surface Water Quality Standards for secondary human contact (Table 206A.1, page 24.) The monitoring frequency is once/week.

E. Total Residual Chlorine (TRC)

The permit requires the discharger to meet a TRC limit of 11.0 ug/l as an instantaneous maximum if chlorination is used for disinfection of the effluent before discharge. This limit is based on Best Professional Judgment and should assure that the Navajo Nation Surface Water Quality Standards for protection of aquatic life (11.0 ug/l) is met in the receiving water when aquatic life is present (Table 206B.2, page 28.) The presence of aquatic life depends on natural background flows. Such background flows are only present during and after storm events in which the discharge should undergo significant dilution. Furthermore, a large portion of the residual chlorine should volatilize. Nevertheless, the permittee should attempt to achieve the lowest possible residual chlorine level while still achieving the limits for fecal coliform. The monitoring frequency is once/day for the effluent and once/month in the receiving water.

F. Ammonia (as un-ionized NH<sub>3</sub>)

The proposed permit establishes a monitoring requirement for ammonia. The monitoring frequency is once/quarter. If analytical results for the first four quarters reveal ammonia levels are below the EPA's National Water Quality Criteria for ammonia, the monitoring frequency will decrease to once/year. The regulations at 40 CFR 122.44(i) allow requirements for monitoring as determined to be necessary.

G. Total Dissolved Solids (TDS)

The proposed permit requires monitoring and reporting of both the influent and effluent TDS, as in the previous permit. The monitored frequency is once/quarter. The regulations at 40 CFR 122.44(i) allow requirements for monitoring as determined to be

necessary.

#### H. pH

The proposed permit requires that effluent pH not fall below 6.5 or above 9.0 standard pH units, consistent with the Navajo Nation Surface Water Quality Standards for the Pueblo Colorado Wash. The monitoring frequency is once/week.

#### VII. Reporting

The proposed permit requires discharge data obtained during the previous three months to be summarized and reported monthly. If there is no discharge for the month, indicate "Zero Discharge." These reports are due January 28, April 28, July 28, and October 28 of each year. Duplicate signed copies of these, and all other reports required herein, shall be submitted to the EPA Regional Administrator and the Navajo Nation EPA.

#### VIII. General Standards

The proposed permit sets general standards that are narrative water quality standards contained in the Navajo Nation Surface Water Quality Standards, Section 203. The general standards are set forth in Section B. (General Discharge Specifications) of the permit.

#### IX. Permit Reopener

At this time, there is no reasonable potential to establish any other water quality-based limits. Should any monitoring indicate that the discharge causes, has the reasonable potential to cause, or contributes to excursion above a water quality criteria, the permit may be reopened for the imposition of water quality-based limits and/or whole effluent toxicity limits. The proposed permit may be modified, in accordance with the requirements set forth at 40 CFR 122.44 and 124.14, to include appropriate conditions or limits to address demonstrated effluent toxicity based on newly available information, or to implement any EPA-approved new Tribal water quality standards.

#### X. Biosolids Requirements

The permittee shall submit a report 60 days prior to disposal of biosolids. The report shall discuss the quantity of biosolids produced, the treatment applied to biosolids including process parameters, disposal methods, and, if land applied, analyses for Arsenic, Cadmium, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Zinc, and Selenium, and for organic-N, ammonium-N, and nitrate-N, all expressed in mg/kg biosolids on a 100% dry weight basis. The permittee shall comply with all standards for biosolids use and disposal of Section 405(d) of the CWA, and 40 CFR Parts 257, 258 and 503.

XI. Endangered Species Act

EPA has determined that discharge in compliance with this permit will have no effect on threatened or endangered species.

XII. Written Comments

Persons who wish to comment upon, object to the proposed action, or request a public hearing pursuant to 40 CFR Section 124.11 should submit their comments and requests in writing within thirty (30) days from the date of the Public Notice, either in person or by mail to:

U.S. Environmental Protection Agency, Region IX  
CWA Standards and Permits Office (WTR-5)  
Attn: Linh Tran  
75 Hawthorne Street  
San Francisco, CA 94105  
Telephone: (415) 972-3511

XIII. Information and Copying

The Administrative Record, which contains the draft NPDES permit, the fact sheet, comments received, and other relevant documents, is available for review and may be obtained by calling or writing to the above address.

All comments or objections received within thirty (30) days from the date of the Public Notice, will be retained and considered in the formulation of the final determination regarding the permit issuance.

XIV. Public Hearing

When public interest warrants, the Regional Administrator shall hold a public hearing and such notice of hearing shall be issued by public notice at least thirty (30) days prior to the hearing date. A request for a public hearing must be in writing and must also state the nature of the issue proposed to be raised in the hearing.